

ENVIRONMENTAL  
CLEARANCE

PARIVESH

(Pro-Active and Responsive Facilitation by Interactive,  
and Virtuous Environmental Single-Window Hub)



Government of India  
Ministry of Environment, Forest and Climate Change  
(Issued by the State Environment Impact Assessment  
Authority(SEIAA), MAHARASHTRA)

To,

The Director  
AMANTHIN INFO PARK PVT. LTD.  
One Indiabulls center, 16th Floor, Tower 2A, Senapati bapat Marg,  
Mumbai-400013 -400703

**Subject:** Grant of Environmental Clearance (EC) to the proposed Project Activity  
under the provision of EIA Notification 2006-regarding

Sir/Madam,

This is in reference to your application for Environmental Clearance (EC)  
in respect of project submitted to the SEIAA vide proposal number  
SIA/MH/INFRA2/410988/2022 dated 29 Dec 2022. The particulars of the  
environmental clearance granted to the project are as below.

- |   |  |
|---|--|
| 1. EC Identification No.                      | EC23B038MH169990   |
| 2. File No.                                   | SIA/MH/INFRA2/410988/2022  |
| 3. Project Type                               | Expansion  |
| 4. Category                                   | B  |
| 5. Project/Activity including<br>Schedule No. | 8(a) Building and Construction projects  |
| 6. Name of Project                            | Proposed Expansion of Data Centre<br>Project by Amanthin Info Parks Pvt. Ltd.<br>located at Plot No. D- 31 and D- 32, TTC<br>Industrial Area, Turbhe, Navi Mumbai,<br>Dist. Thane - 400703 |
| 7. Name of Company/Organization               | AMANTHIN INFO PARK PVT. LTD.   |
| 8. Location of Project                        | MAHARASHTRA  |
| 9. TOR Date                                   | N/A  |

The project details along with terms and conditions are appended herewith from page  
no 2 onwards.

Date: 21/07/2023

(e-signed)  
Pravin C. Darade , I.A.S.  
Member Secretary  
SEIAA - (MAHARASHTRA)

*Note: A valid environmental clearance shall be one that has EC identification  
number & E-Sign generated from PARIVESH. Please quote identification  
number in all future correspondence.*

*This is a computer generated cover page.*

**STATE LEVEL ENVIRONMENT IMPACT ASSESSMENT AUTHORITY**

No. SIA/MH/INFRA2/410988/2022  
Environment & Climate  
Change Department  
Room No. 217, 2<sup>nd</sup> Floor,  
Mantralaya, Mumbai- 400032.

To  
M/s.Amanthin Info Parks Pvt. Ltd.,  
Plot No. D- 31 and D- 32, TTC Industrial Area,  
Turbhe, Navi Mumbai, Dist. Thane.

**Subject** : Environment Clearance for proposed Expansion of Data Centre Project located at Plot No. D- 31 and D- 32, TTC Industrial Area, Turbhe, Navi Mumbai, Dist. Thane by M/s.Amanthin Info Parks Pvt. Ltd.

**Reference** : Application no. SIA/MH/INFRA2/410988/2022

This has reference to your communication on the above-mentioned subject. The proposal was considered by the SEAC-2 in its 196<sup>th</sup> meeting under screening category 8 (a) B2 as per EIA Notification, 2006 and recommend to SEIAA. Proposal then considered in 261<sup>st</sup> (Day-1) meeting of State Level Environment Impact Assessment Authority (SEIAA) held on 09.06.2023.

2. Brief Information of the project submitted by you is as below:-

Sr. No.	Details	Reply
1.	Proposal Number	<b>SIA/MH/INFRA2/410988/2022</b>
2.	Name of Project	Proposed Data Centre Project [IT/ITes] by M/S. AMANTHIN INFO PARKS PVT. LTD. At Plot No. D- 31 and D-32, TTC Industrial Area, Turbhe, Navi Mumbai, Dist. Thane – 400703
3.	Project category	8 (a) B2
4.	Type of Institution	Private Limited
5.	Project Proponent	<b>Name:</b> Mr. Rahul Nair through "AMANTHIN INFO PARKS PVT. LTD"
		<b>Registered address:</b> One India bulls Centre, 16th Floor, Tower 2A, Senapati Bapat Marg, Mumbai, Maharashtra, 400013
		Contact number: 9833510627
		Email: amanthininfo@gmail.com
6.	Consultant	<b>Name:</b> Technogreen Environmental Solutions <b>Accreditation No:</b> NABET/EIA/2124/IA0081 <b>Valid till:</b> July 05,2024
7.	Applied for	Expansion
8.	Location of the project	Plot No. D- 31 and D-32, TTC Industrial Area, Turbhe, Navi Mumbai, Dist. Thane – 400703
9.	Latitude and Longitude	Latitude: 19° 3'52.88"N, Longitude: 73° 1'31.36"E

10.	Plot Area (m <sup>2</sup> )	39,980																				
11.	Deductions (m <sup>2</sup> )	NA																				
12.	Net Plot area (m <sup>2</sup> )	39,980																				
13.	Ground coverage (m <sup>2</sup> ) & %	16,255.62 [40.65%]																				
14.	FSI area (m <sup>2</sup> )	47,416.21																				
15.	Non-FSI area (m <sup>2</sup> )	14,063.22																				
16.	Proposed built-up area (FSI + Non FSI) (sq.m.)	61,479.43																				
17.	TBUA (m <sup>2</sup> ) approved by Planning Authority till date	61,479.43																				
18.	Earlier EC details with Total Construction area, if any.	EC Letter No. EC22B038MH187924 on 04.05.2022 Total construction BUA as per earlier EC - 55,431.61 [53,404.6 FSI + 2,027.01 Non - FSI]																				
19.	Construction completed as per earlier EC (FSI + Non FSI) (sq.m.)	Only site preparation and excavation work has been started on site as per Previous EC granted																				
20.	<table border="1"> <thead> <tr> <th colspan="3">Previous EC / Existing Building</th> <th colspan="3">Proposed Configuration</th> <th rowspan="2">Reason for Modification / Change</th> </tr> <tr> <th>Bldg. Name</th> <th>Configuration</th> <th>Height (m)</th> <th>Bldg. Name</th> <th>Configuration</th> <th>Height (m)</th> </tr> </thead> <tbody> <tr> <td>A- Data Centre Building B - Gate House, B - Substation C - Pump room, D-Pump room 2,</td> <td>G+4 {Data Centre [G+2] 2 Gantry [G+4]}</td> <td>51</td> <td>A1 - Data Centre Building B1 - Pump room, C1 - Pump room, D1 - Security Cabin, E1 - Substation F1 - Gate House 2</td> <td>{[Data hall G+2 + Gantry G+5]}</td> <td>53.2</td> <td rowspan="2">Addition of 1 floor</td> </tr> </tbody> </table>		Previous EC / Existing Building			Proposed Configuration			Reason for Modification / Change	Bldg. Name	Configuration	Height (m)	Bldg. Name	Configuration	Height (m)	A- Data Centre Building B - Gate House, B - Substation C - Pump room, D-Pump room 2,	G+4 {Data Centre [G+2] 2 Gantry [G+4]}	51	A1 - Data Centre Building B1 - Pump room, C1 - Pump room, D1 - Security Cabin, E1 - Substation F1 - Gate House 2	{[Data hall G+2 + Gantry G+5]}	53.2	Addition of 1 floor
	Previous EC / Existing Building			Proposed Configuration			Reason for Modification / Change															
Bldg. Name	Configuration	Height (m)	Bldg. Name	Configuration	Height (m)																	
A- Data Centre Building B - Gate House, B - Substation C - Pump room, D-Pump room 2,	G+4 {Data Centre [G+2] 2 Gantry [G+4]}	51	A1 - Data Centre Building B1 - Pump room, C1 - Pump room, D1 - Security Cabin, E1 - Substation F1 - Gate House 2	{[Data hall G+2 + Gantry G+5]}	53.2	Addition of 1 floor																
21.	Total number of tenements & Shops	Not Applicable																				
22.	Total Population	200																				
23.	Total Water Requirements CMD	Dry season (CMD)		Wet Season (CMD)																		
		Fresh water requirement	32.5	Fresh water requirement	4.8																	
		Flushing water	3.9	Flushing water	3.9																	

		requirement (Recycled)		requirement (Recycled)		
		Gardening (Recycled +Fresh)	32.1	Gardening (Recycled +Fresh)	--	
		<b>Total water requirement</b>	<b>40.7 [32.5 Fresh + 8.2 Recycled]</b>	<b>Total water requirement</b>	<b>8.7 [4.8 Fresh + 3.9 Recycled]</b>	
		Waste water generation	8.2	Waste water generation	68.26	
24.	Under Ground Tank (UGT) location	Domestic Water Tank: 35m <sup>3</sup> × 2Nos. Fire Water Tank: 200m <sup>3</sup> x 2 Nos.				
25.	Source of water	MIDC				
26.	STP Capacity & Technology	Sewage generation in CMD:	8.2			
		STP technology:	Moving Bed Bio-Reactor (MBBR)			
		Capacity of STP (CMD):	STP: 10CMD			
27.	STP Location	Near Open Space [Behind Gantry Building]				
28.	Sewage Generation CMD & % of sewage discharge in sewer line	Sewage Generation: 8.2 CMD and no sewage will be discharged in sewer line during dry season				
29.	Solid Waste Management during Construction Phase	<b>Type</b>	<b>Quantity (kg/d)</b>	<b>Treatment / disposal</b>		
		Dry waste:	144 kg/day	Given to Authorized recyclers		
		Wet waste:	216 kg/day	Treated in OWC		
		<b>Construction and demolition waste (as below)</b>				
		Concrete 23% (M <sup>3</sup> )	294.59	Handed Over to authorized vendors/Recycler		
		Metals 5% (MT)	153.7			
		"Brick & Masonry 31% (M <sup>3</sup> )	496.3			
		Others 1% (MT)	30.74			
Wood 2% (MT)	61.4					
30.	Total Solid Waste Quantities with type during Operation Phase & Capacity of OWC to be installed	<b>Type</b>	<b>Quantity (kg/d)</b>	<b>Treatment / disposal</b>		
		Dry waste:	36 kg/day	Given to Authorized recyclers		
		Wet waste:	24 kg/day	Treated in OWC		
		Hazardous waste: [Used Oil]	26,680 LPA	Authorized vendor		
		E-Waste	188 Kg/year	Authorized vendor		

		STP Sludge (dry)	19 Kg/M	Will be used as manure
		Used Batteries	5,699 Nos/Y	Authorized vendor
31.	R.G. Area in sq.m	RG required	3,998.00 m <sup>2</sup>	
		RG provided on mother earth / ground	4,042.28m <sup>2</sup>	
		Total	4,042.28m <sup>2</sup>	
		Existing trees on plot	201	
		Number of trees to be planted:	2,861	
		a) In RG area:	300Nos. (100sq.m)	
		b) In Miyawaki Plantation (with area)		
		Number of trees to be cut:	26	
		Number of trees to be transplanted:	175	
32.	Power requirement	<b>Operation phase</b>		
		Connected load	103367 KW	
		Demand load	108807 KVA	
		Transformer:	4 X 220kV/22kV [60MVA]	
		DG set:	2200KVA x 58 Nos.	
33.	Details of Energy saving	a) Total energy saving (%): 5% using PPA b) Solar energy (%): 10 % of external lighting load		
34.	D.G. set capacity	2200KVA x 58 Nos.		
35.	No. of 4-W & 2-W Parking with 25% EV	4W-302, 2W- 36 <i>40% of Two Wheelers &amp; Four Wheelers is reserved is EV</i>		
36.	No. & capacity of Rain water harvesting tanks /Pits	Level of the Ground water table:	2-4 m BGL	
		Size and no of RWH tank(s) and Quantity	450 Cum x 1No. 30.0m x 5.0m x 3.0m	
		Details of UGT tanks if any:	450 Cum x 1Nos 30.0m x 5.0m x 3.0m	
37.	Total Project Cost (Rs.)	2,417.5 Cr.		
38.	EMP Cost	Capital Cost: 6.72 CR & O&M Cost: 0.64 Cr./Year		
39.	CER Details with justification if any....as per MoEF&CC circular dated 01/05/2018	As per MoEF&CC, GoI, OM no. F.No. 22-65/2017-IA.III dated 20th October 2020 CER to be integrated with EMP ,hence separate CER proposal is not included		
40.	Details of Court cases / litigations w.r.t. the project and project location if any.	NA		

The comparative statement showing project details as per earlier EC and proposal under consideration is as below:

Sn.	Particulars	Existing	Proposed	Difference / change
1	Plot Area – m <sup>2</sup>	39,980.00	39,980.00	No Change

2	FSI Area - m <sup>2</sup>	53,404.60	47,416.21	Decreased by 5,988.39m <sup>2</sup>
3	Non-FSI Area - m <sup>2</sup>	2,027.01	14,063.22	Increased by 12,036.21m <sup>2</sup>
4	Total BUA Area - m2	55,431.61	61,479.43	Increased by 6,047.82m <sup>2</sup>
5	Ground Coverage	16,283.89m <sup>2</sup> [40.73%]	16,255.62m <sup>2</sup> [40.65%]	Decreased by 28.27m <sup>2</sup>
6	Green Area	4,005.00 m <sup>2</sup>	4,042.28 m <sup>2</sup>	Increased by 37.28m <sup>2</sup>
7	No. of buildings & Configuration	A- Data Centre Building – G+4 {Data Centre [G+2] 2 Gantry [G+4]} B - Gate House, B - Substation C - Pump room, D - Pump room 2,	A1 - Data Centre Building G+5 {[Data hall G+2 + Gantry G+5]},  B1 - Pump room, C1 - Pump room, D1 - Security Cabin, E1 - Substation F1 - Gate House 2	Addition of 1 floor & mezzanine area in Gantry
8	Project Cost	Rs. 2,417.5Cr.	Rs. 2,417.5Cr.	No Change
9	EMP Cost	Capital Cost: 6.72 Cr. & O&M Cost: 0.64Cr./Year	Capital Cost: 6.72 Cr. & O&M Cost:0.64Cr./Year	No Change
10	Population	200	200	No Change
11	Building height	51.0	53.2	Increased by 2.2m
12	Total Water Demand	40.7CMD	40.7CMD	No Change
13	Sewage Generation	8.2CMD	8.2CMD	No Change

3. The proposal has been considered by SEIAA in its 260<sup>th</sup> (Day-1) meeting held on 09.06.2023 and decided to accord Environment Clearance to the said project under the provisions of Environment Impact Assessment Notification, 2006 subject to implantation of following terms and conditions-

**Specific Conditions:**

**A. SEAC Conditions-**

1. PP to submit IOD/IOA/Concession Document/Plan Approval or any other form of documents as applicable clarifying its conformity with local planning rules and provisions thereunder as per the circular dated 30.01.2014 issued by the Environment Department, Govt. of Maharashtra.

2. PP to obtain following NOCs & remarks as per amended planning:  
a) Water supply; b) CFO NOC.
3. PP to obtain certified six-monthly compliance report of earlier EC from Regional Office, MOEF&CC, Nagpur.
4. PP to relocate STP as it is coming in drive-way.
5. PP to maintain adequate distance between STP, OWC, Hazardous waste storage area & RG area.
6. PP to ensure that the energy savings from renewable sources shall be minimum 5 % or submit registered power purchase agreement with green energy supplier for utilizing 10% green energy within the project site.
7. PP to relocate parking proposed on RWH tank.
8. PP to ensure that the treated water parameters are as per NGT norms.
9. PP to obtain revised PESO license from competent authority for storage of HSD.
10. PP to deduct area of services provided from RG area and submit revised RG area calculations with triangulation method.

**B. SEIAA Conditions-**

1. PP has provided mandatory RG area of 4042.28 m<sup>2</sup> on ground. Local planning authority to ensure the compliance of the same.
2. This EC is restricted up to 46.80 m height as per CFO NOC.
3. PP to keep open space unpaved so as to ensure permeability of water. However, whenever paving is deemed necessary, PP to provide grass pavers of suitable types & strength to increase the water permeable area as well as to allow effective fire tender movement.
4. PP to achieve at least 5% of total energy requirement from solar/other renewable sources.
5. PP Shall comply with Standard EC conditions mentioned in the Office Memorandum issued by MoEF& CC vide F.No.22-34/2018-IA.III dt.04.01.2019.
6. SEIAA after deliberation decided to grant EC for – FSI- 39,890.39m<sup>2</sup>, Non FSI- 4,122.64 m<sup>2</sup>, Total BUA- 44,013.03 m<sup>2</sup>. (Plan approval No-EE/Dn-II/SPA/MHP/C16068/2022, dated-02.11.2022) (Restricted as per approval)

**General Conditions:**

**a) Construction Phase :-**

- I. The solid waste generated should be properly collected and segregated. Dry/inert solid waste should be disposed of to the approved sites for land filling after recovering recyclable material.
- II. Disposal of muck, Construction spoils, including bituminous material during construction phase should not create any adverse effect on the neighbouring communities and be disposed taking the necessary precautions for general safety and health aspects of people, only in the approved sites with the approval of competent authority.
- III. Any hazardous waste generated during construction phase should be disposed of as per applicable rules and norms with necessary approvals of the Maharashtra Pollution Control Board.
- IV. Adequate drinking water and sanitary facilities should be provided for construction workers at the site. Provision should be made for mobile toilets. The safe disposal of wastewater and solid wastes generated during the construction phase should be ensured.
- V. Arrangement shall be made that waste water and storm water do not get mixed.

- VI. Water demand during construction should be reduced by use of pre-mixed concrete, curing agents and other best practices.
- VII. The ground water level and its quality should be monitored regularly in consultation with Ground Water Authority.
- VIII. Permission to draw ground water for construction of basement if any shall be obtained from the competent Authority prior to construction/operation of the project.
- IX. Fixtures for showers, toilet flushing and drinking should be of low flow either by use of aerators or pressure reducing devices or sensor based control.
- X. The Energy Conservation Building code shall be strictly adhered to.
- XI. All the topsoil excavated during construction activities should be stored for use in horticulture / landscape development within the project site.
- XII. Additional soil for levelling of the proposed site shall be generated within the sites (to the extent possible) so that natural drainage system of the area is protected and improved.
- XIII. Soil and ground water samples will be tested to ascertain that there is no threat to ground water quality by leaching of heavy metals and other toxic contaminants.
- XIV. PP to strictly adhere to all the conditions mentioned in Maharashtra (Urban Areas) Protection and Preservation of Trees Act, 1975 as amended during the validity of Environment Clearance.
- XV. The diesel generator sets to be used during construction phase should be low sulphur diesel type and should conform to Environments (Protection) Rules prescribed for air and noise emission standards.
- XVI. Vehicles hired for transportation of Raw material shall strictly comply the emission norms prescribed by Ministry of Road Transport & Highways Department. The vehicle shall be adequately covered to avoid spillage/leakages.
- XVII. Ambient noise levels should conform to residential standards both during day and night. Incremental pollution loads on the ambient air and noise quality should be closely monitored during construction phase. Adequate measures should be made to reduce ambient air and noise level during construction phase, so as to conform to the stipulated standards by CPCB/MPCB.
- XVIII. Diesel power generating sets proposed as source of backup power for elevators and common area illumination during construction phase should be of enclosed type and conform to rules made under the Environment (Protection) Act, 1986. The height of stack of DG sets should be equal to the height needed for the combined capacity of all proposed DG sets. Use low sulphur diesel is preferred. The location of the DG sets may be decided with in consultation with Maharashtra Pollution Control Board.
- XIX. Regular supervision of the above and other measures for monitoring should be in place all through the construction phase, so as to avoid disturbance to the surroundings by a separate environment cell /designated person.

**B) Operation phase:-**

- I. a) The solid waste generated should be properly collected and segregated. b) Wet waste should be treated by Organic Waste Converter and treated waste (manure) should be utilized in the existing premises for gardening. And, no wet garbage will be disposed outside the premises. c) Dry/inert solid waste should be disposed of to the approved sites for land filling after recovering recyclable material.



- II. E-waste shall be disposed through Authorized vendor as per E-waste (Management and Handling) Rules, 2016.
- III. a) The installation of the Sewage Treatment Plant (STP) should be certified by an independent expert and a report in this regard should be submitted to the MPCB and Environment department before the project is commissioned for operation. Treated effluent emanating from STP shall be recycled/ reused to the maximum extent possible. Treatment of 100% grey water by decentralized treatment should be done. Necessary measures should be made to mitigate the odour problem from STP. b) PP to give 100 % treatment to sewage /Liquid waste and explore the possibility to recycle at least 50 % of water, Local authority should ensure this.
- IV. Project proponent shall ensure completion of STP, MSW disposal facility, green belt development prior to occupation of the buildings. As agreed during the SEIAA meeting, PP to explore possibility of utilizing excess treated water in the adjacent area for gardening before discharging it into sewer line No physical occupation or allotment will be given unless all above said environmental infrastructure is installed and made functional including water requirement.
- V. The Occupancy Certificate shall be issued by the Local Planning Authority to the project only after ensuring sustained availability of drinking water, connectivity of sewer line to the project site and proper disposal of treated water as per environmental norms.
- VI. Traffic congestion near the entry and exit points from the roads adjoining the proposed project site must be avoided. Parking should be fully internalized and no public space should be utilized.
- VII. PP to provide adequate electric charging points for electric vehicles (EVs).
- VIII. Green Belt Development shall be carried out considering CPCB guidelines including selection of plant species and in consultation with the local DFO/ Agriculture Dept.
- IX. A separate environment management cell with qualified staff shall be set up for implementation of the stipulated environmental safeguards.
- X. Separate funds shall be allocated for implementation of environmental protection measures/EMP along with item-wise breaks-up. These cost shall be included as part of the project cost. The funds earmarked for the environment protection measures shall not be diverted for other purposes.
- XI. The project management shall advertise at least in two local newspapers widely circulated in the region around the project, one of which shall be in the Marathi language of the local concerned within seven days of issue of this letter, informing that the project has been accorded environmental clearance and copies of clearance letter are available with the Maharashtra Pollution Control Board and may also be seen at Website at [parivesh.nic.in](http://parivesh.nic.in)
- XII. A copy of the clearance letter shall be sent by proponent to the concerned Municipal Corporation and the local NGO, if any, from whom suggestions/representations, if any, were received while processing the proposal. The clearance letter shall also be put on the website of the Company by the proponent.
- XIII. The proponent shall upload the status of compliance of the stipulated EC conditions, including results of monitored data on their website and shall update the same periodically. It shall simultaneously be sent to the Regional Office of MoEF, the respective Zonal Office of CPCB and the SPCB. The criteria pollutant levels namely;

SPM, RSPM. SO<sub>2</sub>, NO<sub>x</sub> (ambient levels as well as stack emissions) or critical sector parameters, indicated for the project shall be monitored and displayed at a convenient location near the main gate of the company in the public domain.

**C) General EC Conditions:-**

- I. PP has to strictly abide by the conditions stipulated by SEAC& SEIAA.
  - II. If applicable Consent for Establishment" shall be obtained from Maharashtra Pollution Control Board under Air and Water Act and a copy shall be submitted to the Environment department before start of any construction work at the site.
  - III. Under the provisions of Environment (Protection) Act, 1986, legal action shall be initiated against the project proponent if it was found that construction of the project has been started without obtaining environmental clearance.
  - IV. The project proponent shall also submit six monthly reports on the status of compliance of the stipulated EC conditions including results of monitored data (both in hard copies as well as by e-mail) to the respective Regional Office of MoEF, the respective Zonal Office of CPCB and the SPCB.
  - V. The environmental statement for each financial year ending 31st March in Form-V as is mandated to be submitted by the project proponent to the concerned State Pollution Control Board as prescribed under the Environment (Protection) Rules, 1986, as amended subsequently, shall also be put on the website of the company along with the status of compliance of EC conditions and shall also be sent to the respective Regional Offices of MoEF by e-mail.
  - VI. No further Expansion or modifications, other than mentioned in the EIA Notification, 2006 and its amendments, shall be carried out without prior approval of the SEIAA. In case of deviations or alterations in the project proposal from those submitted to SEIAA for clearance, a fresh reference shall be made to the SEIAA as applicable to assess the adequacy of conditions imposed and to add additional environmental protection measures required, if any.
  - VII. This environmental clearance is issued subject to obtaining NOC from Forestry & Wild life angle including clearance from the standing committee of the National Board for Wild life as if applicable & this environment clearance does not necessarily implies that Forestry & Wild life clearance granted to the project which will be considered separately on merit.
4. The environmental clearance is being issued without prejudice to the action initiated under EP Act or any court case pending in the court of law and it does not mean that project proponent has not violated any environmental laws in the past and whatever decision under EP Act or of the Hon'ble court will be binding on the project proponent. Hence this clearance does not give immunity to the project proponent in the case filed against him, if any or action initiated under EP Act.
5. This Environment Clearance is issued purely from an environment point of view without prejudice to any court cases and all other applicable permissions/ NOCs shall be obtained before starting proposed work at site.
6. In case of submission of false document and non-compliance of stipulated conditions, Authority/ Environment Department will revoke or suspend the Environment clearance without any intimation and initiate appropriate legal action under Environmental Protection Act, 1986.
7. Validity of Environment Clearance: The environmental clearance accorded shall be valid

as per EIA Notification, 2006, amended from time to time.

8. The above stipulations would be enforced among others under the Water (Prevention and Control of Pollution) Act, 1974, the Air (Prevention and Control of Pollution) Act, 1981, the Environment (Protection) Act, 1986 and rules there under, Hazardous Wastes (Management and Handling) Rules, 1989 and its amendments, the public Liability Insurance Act, 1991 and its amendments.

9. Any appeal against this Environment clearance shall lie with the National Green Tribunal (Western Zone Bench, Pune), New Administrative Building, 1<sup>st</sup> Floor, D-Wing, Opposite Council Hall, Pune, if preferred, within 30 days as prescribed under Section 16 of the National Green Tribunal Act, 2010.



Pravin Darade  
(Member Secretary, SEIAA)

Copy to:

1. Chairman, SEIAA, Mumbai.
2. Secretary, MoEF & CC, IA- Division MOEF & CC
3. Member Secretary, Maharashtra Pollution Control Board, Mumbai.
4. Regional Office MoEF & CC, Nagpur
5. District Collector, Thane.
6. Commissioner, Navi Mumbai Municipal Corporation
7. Regional Officer, Maharashtra Pollution Control Board, Navi Mumbai.

Signature Not Verified

Digitally signed by Shri Pravin C. Darade, I.A.S.  
Member Secretary  
Date: 7/21/2023 9:15:20 PM